

Food Establishment Inspection Report



Wichita Falls - Wichita County
Public Health District
1700 Third Street
Wichita Falls, TX 76301
940-761-7800

SITE NO. 6603 **INV NO.** 1 **IR NO.** **DATE** 04/06/2011 **INSPECTION TIME** **INSPECTOR** Railsback, Brian

SITE INFORMATION
CHRIST ACADEMY
5105 STONE LAKE DR
WICHITA FALLS TX 76309
940-692-2853

INVENTORY/MANAGER
Process 3 - Exempt

SERVICE TYPE/FREQUENCY
Inspection- Regular
Inspected 4 Times per Year

Scheduled calender inspections.

Violations: Critical - 1 Score: 97

CRITICAL VIOLATIONS SUMMARY

<u>CODE</u>	<u>DESCRIPTION</u>	<u>POINTS</u>	<u>CORRECTED</u>
16	Handwash Facilities Adequate & Access	3	_____

CRITICAL VIOLATIONS DETAIL

<u>CODE</u>	<u>DESCRIPTION</u>
16	Texas Food Establishment Rules Page 107 §229.166 (h) Plumbing, location and placement. (1) Handwashing facilities. A handwashing facility shall be located: (A) to allow convenient use by employees in food preparation, food dispensing, and warewashing areas; and (B) in, or immediately adjacent to, toilet rooms. To Wit: Hand wash sink in kitchen has insufficient hot water and pressure, must be repaired. All other hand wash sinks worked properly

I HEREBY, ACKNOWLEDGE THE ISSUANCE AND RECEIPT OF THIS OFFICIAL Food Establishment Inspection Report.

Brian Railsback, Public Health Officer

OWNER / MANAGER SIGNATURE

OWNER / MANAGER PRINT NAME