

Food Establishment Inspection Report

Wichita Falls - Wichita County
 Public Health District
 1700 Third Street
 Wichita Falls, TX 76301
 940-761-7800

| SITE NO. | INV NO. | IR NO. | DATE | INSPECTION TIME | INSPECTOR |
|----------|---------|--------|------------|-----------------|--------------|
| 6995 | 1 | | 01/19/2010 | | Baxter, Mike |

SITE INFORMATION
 ELITE DAY SCHOOL
 1606 HARRISON
 WICHITA FALLS TX 76309
 940-642-4627

INVENTORY/MANAGER
 Process 2

SERVICE TYPE/FREQUENCY
 Permit Inspection
 Permit Granted
 Inspect 1 time annually

Violations: Non-Critical - 1 Score: 100

NON-CRITICAL VIOLATIONS SUMMARY

| <u>CODE</u> | <u>DESCRIPTION</u> | <u>POINTS</u> | <u>CORRECTED</u> |
|-------------|--------------------|---------------|------------------|
| 28 | OTHER VIOLATIONS | 0 | _____ |

NON-CRITICAL VIOLATIONS DETAIL

| <u>CODE</u> | <u>DESCRIPTION</u> |
|-------------|--|
| 28 | Texas Food Establishment Rules OTHER VIOLATIONS- REQUIRE CORRECTIVE ACTION , NOT TO EXCEED 90 DAYS OR NEXT INSPECTION, WHICHEVER COMES FIRST. To Wit: no fire extinguisher system over gas stove To Correct: Owner needs to install a fire extinguishing system over the gas stove. Tanya agreed to do this within 30 days from today . |

I HEREBY, ACKNOWLEDGE THE ISSUANCE AND RECEIPT OF THIS OFFICIAL Food Establishment Inspection Report.

Mike Baxter, Public Health Officer

OWNER / MANAGER SIGNATURE

OWNER / MANAGER PRINT NAME

Food Establishment Inspection Report

Wichita Falls - Wichita County
 Public Health District
 1700 Third Street
 Wichita Falls, TX 76301
 940-761-7800

| SITE NO. | INV NO. | IR NO. | DATE | INSPECTION TIME | INSPECTOR |
|----------|---------|--------|------------|-----------------|--------------|
| 6995 | 1 | | 01/19/2010 | | Baxter, Mike |

SITE INFORMATION
 ELITE DAY SCHOOL
 1606 HARRISON
 WICHITA FALLS TX 76309
 940-642-4627

INVENTORY/MANAGER
 Process 2

SERVICE TYPE/FREQUENCY
 Permit Inspection
 Permit Granted
 Inspect 1 time annually

Violations: Non-Critical - 1 Score: 100

NON-CRITICAL VIOLATIONS SUMMARY

| <u>CODE</u> | <u>DESCRIPTION</u> | <u>POINTS</u> | <u>CORRECTED</u> |
|-------------|--------------------|---------------|------------------|
| 28 | OTHER VIOLATIONS | 0 | _____ |

NON-CRITICAL VIOLATIONS DETAIL

| <u>CODE</u> | <u>DESCRIPTION</u> |
|-------------|--|
| 28 | Texas Food Establishment Rules OTHER VIOLATIONS- REQUIRE CORRECTIVE ACTION , NOT TO EXCEED 90 DAYS OR NEXT INSPECTION, WHICHEVER COMES FIRST. To Wit: no fire extinguisher system over gas stove To Correct: Owner needs to install a fire extinguishing system over the gas stove. Tanya agreed to do this within 30 days from today . |

I HEREBY, ACKNOWLEDGE THE ISSUANCE AND RECEIPT OF THIS OFFICIAL Food Establishment Inspection Report.

Mike Baxter, Public Health Officer

OWNER / MANAGER SIGNATURE

OWNER / MANAGER PRINT NAME