

Food Establishment Inspection Report



Wichita Falls - Wichita County
Public Health District
1700 Third Street
Wichita Falls, TX 76301
940-761-7800

SITE NO. 6419 **INV NO.** 1 **IR NO.** **DATE** 05/06/2010 **INSPECTION TIME** **INSPECTOR** Railsback, Brian

SITE INFORMATION
SCOTLAND PARK ELEM.
1415 N 5TH ST
WICHITA FALLS TX 76306
940-235-1180

INVENTORY/MANAGER
Process 3 - Exempt

SERVICE TYPE/FREQUENCY
Inspection- Regular
Inspected 3 Times per Year

Violations: Critical - 1 Score: 97

CRITICAL VIOLATIONS SUMMARY

<u>CODE</u>	<u>DESCRIPTION</u>	<u>POINTS</u>	<u>CORRECTED</u>
16	Handwash Facilities Adequate & Access	3	_____

CRITICAL VIOLATIONS DETAIL

CODE **DESCRIPTION**

16 Texas Food Establishment Rules

Page 107
§229.166

(h) Plumbing, location and placement.

(1) Handwashing facilities. A handwashing facility shall be located:
(A) to allow convenient use by employees in food preparation, food dispensing, and warewashing areas; and
(B) in, or immediately adjacent to, toilet rooms.

To Wit: Hand wash sink by ice machine is not working, kitchen has 4 other hand wash sinks they are using

To Correct: Corrections must be made by 5-10-10

I HEREBY, ACKNOWLEDGE THE ISSUANCE AND RECEIPT OF THIS OFFICIAL Food Establishment Inspection Report.

Brian Railsback, Public Health Officer

OWNER / MANAGER SIGNATURE

OWNER / MANAGER PRINT NAME